



**MADHYA BHOTEKOSHI
JALAVIDYUT COMPANY LIMITED**

**Middle Bhotekoshi
Hydroelectric Project
(102 MW)**

ADDENDUM No. 4

Lot 1: Civil and Hydro-Mechanical Works (EPC Contract)

Contract Identification No.: MBJCL/MBKHEP/068/69/EPC-1

Table of Content:

Table of Content:.....	2
1 Introduction	3
2 Changes to the Volume 1 Bidding Forms	3
3 Changes to the Volume 1 Bid Price Schedule	3
4 Changes to the Volume 3 Civil Works Specifications.....	4
5 Additional Section 17 to Volume 3 Civil Works Specifications.....	4
Appendix 1	5

1 Introduction

It has become necessary to introduce a number of changes to the Bidding Documents and therefore this Addendum No. 4 has been issued.

The changes are of both contractual and technical natures and are detailed in the following sections.

2 Changes to the Volume 1 Bidding Forms

The following change shall be made to the form of the **Bid Security**:

The following existing text at the end of this form shall be deleted:

This guarantee will expire: (a) if the Bidder is the successful Bidder, upon our receipt of copies of the Contract Agreement signed by the Bidder and the Performance Security issued to you upon the instruction of the Bidder; and (b) if the Bidder is not the successful Bidder, upon the earlier of (i) our receipt of a copy your notification to the Bidder of the name of the successful Bidder; or (ii) 30 days after the expiration of the Bidder's Bid.

and replaced with the following new text:

This guarantee will expire: (a) if the Bidder is the successful Bidder, upon our receipt of copies of the Contract Agreement signed by the Bidder and the Performance Security issued to you upon the instruction of the Bidder; and (b) if the Bidder is not the successful Bidder, upon the earlier of (i) our receipt of a copy your notification to the Bidder of the name of the successful Bidder; or (ii) 60 days after the expiration of the Bidder's Bid.

3 Changes to the Volume 1 Bid Price Schedule

The following texts shall be added at the end of Milestones (MS) table (**Refer Addendum No. 2 APPENDIX 1 BID PRICE SCHEDULE (New Format)**):

MS-24: Another contractor is carrying out the excavation works for the diversion tunnel, working only from the outlet (downstream) portal. It is foreseen that he shall have completed 330m of tunnel excavation by the 31st of January 2014, at which time that part of the diversion tunnel will be handed over to this contractor. If by the time of handover, the remaining length of excavation would exceed 20m, then this contractor shall complete them. The payment for the additional length of diversion tunnel shall be made on the basis of running meter length derived from the quoted rate of MS-24 for 20m length and of other applicable tunnel rates (BoQ Item No. 1.6) from the Bill of Quantities of the Bid Price Schedule.

4 Changes to the Volume 3 Civil Works Specifications

The following change shall be made to Section 2, Paragraph 2.18.3.2 page 54:

The following existing text of this page shall be deleted:

- (6) Unless otherwise specified or shown on the Construction Drawings, concrete class C20/25 (max. aggregate size 38 mm) with the addition of an approved non-shrink agent shall be used for embedding of equipment in second stage concrete. However, the Employer's Representative may order certain parts of the second stage concrete to be executed as class C20/25 with max. aggregate size of 19 mm.

and replaced with the following new text:

- (6) Unless otherwise specified or shown on the Construction Drawings, concrete class C30/37 (max. aggregate size 19 mm) with the addition of an approved non-shrink agent shall be used for embedding of equipment in second stage concrete.

5 Additional Section 17 to Volume 3 Civil Works Specifications

A new Section 17 Air Conditioning and Ventilation System, enclosed in Appendix 1, has been added and shall be taken into consideration by the Bidders and the Contractor.

Appendix 1

Volume 3 Civil Specifications

Section 17 Air Conditioning and Ventilation System